COMMONWEALTH OF KENTUCKY

BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF TRIMBLE COUNTY)		
WATER DISTRICT NO. 1 FOR A DEVIATION)		
FROM 807 KAR 5:066, SECTION 5(4))	CASE NO.	10418
REGARDING WATER STORAGE)		

ORDER

By letter received October 17, 1988, Trimble County Water District No. 1 ("Trimble Water") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a utility to provide water storage to insure a minimum of one day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

- Trimble Water's current water storage capacity is
 223,000 gallons.
- 2. Trimble Water's average daily water usage including unaccounted-for-water is 243,758 gallons.
- 3. Because of the time needed to plan, finance and implement a program to increase its water storage facilities, Trimble Water should be granted a deviation from 807 KAR 5:066, Section 5(4) until January 1, 1992 to bring it within compliance of the Commission's water storage requirements.

IT IS THEREFORE ORDERED that:

- 1. Trimble Water be and it hereby is granted a deviation from 807 KAR 5:066, Section 5(4) until January 1, 1992.
- 2. Trimble Water shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to the expiration date of the deviation herein granted.

Done at Frankfort, Kentucky, this 22nd day of November, 1988.

PUBLIC SERVICE COMMISSION

Chairman

Vice Chairman

,

ATTEST: